ITIS BV
Columbusweg 64
NL-4462 HB Goes
T +31 113568515
info@itis-nl.com
www.itis-nl.com

Test certificate:
202400202-C001

ISO 10497 / API 607
FIRE TEST QUALIFICATION CERTIFICATE

This certificate is to certify that the valve below has been tested in accordance with, and meets the requirements for operability, through seat leakage and external leakage stated in ISO 10497:2010 'Testing of valves – Fire type-testing requirements' and API Standard 607, seventh edition June 2016 'Fire Test for Quarter-turn Valves

Test valve details

Manufacturer	:	COMEVAL VALVE SYSTEMS S.L. y CIA
Address	:	Les Rotes 15, 46540 El Puig, Valencia (ES)
Brand	:	UNIFLOW
Nominal size	:	NPS 3 / DN80
Pressure rating	:	Class 150
Flow direction	:	Bi-directional
Valve type	:	Gate valve
Weight	:	34Kg
Bore	:	Full bore
Drawing number	:	Gate_valve_dn80_class150-uniflow-90-general_drawing-en rev230309 date: 09-03-2023
Body material	:	A216 WCB
Body/bonnet gasket	:	SS304+Graphite
Seat material	:	A105+13Cr
Stem seal material	:	Graphite
Gearbox	:	N/A

According to ISO 10497/API 607, the specified range for covering other sizes/pressure classes is:

Tested valve	Scope of Size	Scope of pressure rating
NPS 3 Class 150	NPS 3; 4; 5; 6 API 6D NPS $3^1/_8$; $4^1/_{16}$; $5^1/_8$; $7^1/_{16}$ API 6A DN 80; 100; 125; 150	Class 150; 300 PN 10; 16; 25; 40

Disclaimer: Under no circumstances ITIS B.V. can be held responsible applying the above mentioned covering range
PN pressure designation only applicable according to ISO 10497:2010

This certificate is issued under the provision that the Raad voor Accreditatie does not assume any liability and refers to the above mentioned test valve. This certificate does not imply assessment of the production of the valves and is only valid in conjunction with the full ITIS BV test report number 202400202-R002.

Approved signatory		
J. van der Hoeff 11-06-2024		